

Annual Drinking Water Quality Report

TX1090025

WOODROW OSCEOLA WSC BLANTON WELL PLANT 1

Annual Water Quality Report for the period of January 1 to December 31, 2013

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name **Malcolm Tucker**

Phone **254 221 0816**

Estes reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254)221-0816.

WOODROW OSCEOLA WSC BLANTON WELL PLANT 1 is Ground Water

Monthly Board Meeting: Second Tuesday of each Month at 6:30pm at main office
1147 FM 934 Blum TX

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPA's Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic waste water discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
1 - BLANTON / FM 934	FM 934	GW	<u>Y</u>	<u>1147 FM 934</u>
2 - FREEMAN	HCR 1439	GW	<u>Y</u>	<u>318 HCR 1439</u>
7 - CR 1414	HCR 1414	GW	<u>Y</u>	<u>960 HCR 1414</u>

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Malcolm Tucker @ 254 221 0816

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Total Trihalomethanes (TTHM)	2013	4.18	0 - 4.18	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	2013	0.0456	0.043 - 0.0456	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	2013	1.61	0 - 1.61	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	2013	0.465	0.444 - 0.465	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2013	0.055	0.044 - 0.055	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Selenium	2013	1.06	0 - 1.06	50	50	ppb	N	Discharge from petroleum and metal refineries; Erosion of natural deposits; Discharge from mines.

Violations Table

Chlorine			
Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.			
Violation Type	Violation Begin	Violation End	Violation Explanation
Disinfectant Level Quarterly Operating Report (DLQOR).	10/01/2013	12/31/2013	All water monitoring and testing was carried out but due to an over-site the report for the quarter was not submitted on time. The report has now been submitted.

The following table shows the monitoring results for the year 2013 indicated by, High, Maximum, Minimum and Off Line.

High = Highest reading indicated during the year

Minimum = Lowest reading indicated during the year

Average = The average of all readings taken during the year

Off Line = Indicates that system was off line during that test period (Normally 24 hour cycles)

Sterilization is obtained by the use of Chlorine gas injected at the point of origin.

YEAR 2013
January - December 2013

BLANTON WELL (1090025)(39545-0001)			
	Average	High	Low
PSI	55.29	64.93	39.20
CHLORINE RESIDUAL	1.56	3.08	0.50
CHLORINE WEIGHT	79.24	150.00	Off Line
GROUND STORAGE TANK LEVEL	14.74	17.48	Off Line
MONTHLY FLOW TOTAL	44,978.79	133,633.97	Off Line
CHLORINE USE	3.48	149.11	Off Line
PH	7.26	8.18	0.16
WATER TEMP	74.64	89.25	47.40
DAILY MAXIMUM FLOW	132.86	150.68	Off Line
FREEMAN WELL (1090025)(39209-0001)			
		0.00	0.00
PSI	52.45	53.04	51.85
CHLORINE RESIDUAL	1.53	2.90	0.41
CHLORINE WEIGHT	78.96	150.00	Off Line
GROUND STORAGE TANK LEVEL	19.56	22.05	12.42
ELEVATED TANK LEVEL	26.75	28.12	25.37
MONTHLY FLOW TOTAL	89,007.87	283,290.78	Off Line
CHLORINE USE	5.03	85.00	Off Line
PH	7.65	14.00	4.20
WATER TEMP	74.80	88.05	58.61
DAILY MAXIMUM FLOW	186.16	262.74	Off Line
Woodrow #7			
		0.00	0.00
PSI	82.34	95.74	64.90
CHLORINE RESIDUAL	1.26	4.00	0.50
CHLORINE WEIGHT	82.60	150.00	Off Line
GROUND STORAGE TANK LEVEL	19.24	24.00	Off Line
MONTHLY FLOW TOTAL	67,059.69	368,700.00	Off Line
CHLORINE USE	31.67	150.00	Off Line
PH	8.04	9.71	Off Line
WATER TEMP	79.07	86.54	61.81
DAILY MAXIMUM FLOW	161.62	247.00	Off Line