

Annual Drinking Water Quality Report

TX1090025

WOODROW OSCEOLA WSC BLANTON WELL PLANT 1

Annual Water Quality Report for the period of January 1 to December 31, 2014

This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

For more information regarding this report contact:

Name Malcolm Tucker

Phone 254 221 0816

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (254 221-0816).

WOODROW OSCEOLA WSC BLANTON WELL PLANT 1 is Ground Water

Member input is always welcome at the regular monthly

Board Meeting Held the second Tuesday of each month at

the service center 1147 FM 934 at 18:30hrs.

Sources of Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.

- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

You may be more vulnerable than the general population to certain microbial contaminants, such as *Cryptosporidium*, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* are available from the Safe Drinking Water Hotline (800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Information about Source Water Assessments

A Source Water Susceptibility Assessment for your drinking water source(s) is currently being updated by the Texas Commission on Environmental Quality. This information describes the susceptibility and types of constituents that may come into contact with your drinking water source based on human activities and natural conditions. The information contained in the assessment allows us to focus source water protection strategies.

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL:
<http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name		Type of Water	Report Status	Location
1 - BLANTON / FM 934	FM 934	GW	<u>Y</u>	<u>1147 FM 934</u>
2 - FREEMAN	HCR 1439	GW	<u>Y</u>	<u>318 HCR 1439</u>
7 - CR 1414	HCR 1414	GW	<u>Y</u>	<u>960 HCR 1414</u>

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Malcolm Tucker at 254 221 0816.

Water Quality Test Results

Definitions:	The following tables contain scientific terms and measures, some of which may require explanation.
Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

BLANTON WELL (1090025)(39545-0001)	Average Day	High	Low	Year Average Gallons
PSI	54.97	64.21	46.14	
CHLORINE RESIDUAL (ppm)	1.60	3.75	0.63	
CHLORINE WEIGHT	72.87	150.00	5.05	
GROUND STORAGE TANK LEVEL (feet)	15.92	17.08	13.39	
MONTHLY FLOW TOTAL (gallons)	50,826.12	135,812.72	Off Line	18,551,534.07
CHLORINE USE	3.66	143.77	0.11	
PH	7.83	8.08	7.66	
WATER TEMP	73.21	88.23	45.16	
DAILY MAXIMUM FLOW (gpm)	148.21	151.48	Off Line	
FREEMAN WELL (1090025)(39209-0001)				
PSI	51.61	53.68	40.87	
CHLORINE RESIDUAL (ppm)	1.40	2.48	0.34	
CHLORINE WEIGHT	79.96	150.00	3.74	
GROUND STORAGE TANK LEVEL (feet)	19.88	21.52	16.12	
ELEVATED TANK LEVEL	24.82	29.60	Off Line	
MONTHLY FLOW TOTAL (gallons)	103,806.56	257,314.92	Off Line	37,889,395.95
CHLORINE USE	5.10	14.01	Off Line	
PH	7.73	8.03	Off Line	
WATER TEMP	74.20	86.56	56.01	
DAILY MAXIMUM FLOW (gpm)	234.07	246.59	Off Line	
WOODROW WELL (1090025)(39209-0003)				
PSI	81.88	93.30	69.95	
CHLORINE RESIDUAL (ppm)	1.56	3.26	0.60	
CHLORINE WEIGHT	77.56	150.00	1.46	
GROUND STORAGE TANK LEVEL (feet)	20.29	21.90	2.34	
MONTHLY FLOW TOTAL (gallons)	74,010.96	261,439.39	Off Line	27,014,000.52
CHLORINE USE	59.22	150.00	0.31	
PH	8.35	9.12	7.55	
WATER TEMP	78.35	87.48	63.60	
DAILY MAXIMUM FLOW (gpm)	224.45	244.42	Off Line	
CHLORINE USE YEAR AVERAGE DAILY	1.52	3.16	0.52	
BLANTON 123 SYSTEM DAILY AVERAGE GALLONS	228,643.65			83,454,930.55

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2014	1	1.1 - 1.1	No goal for the total	60	ppb	N	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2014	17	16.8 - 16.8	No goal for the total	80	ppb	N	By-product of drinking water disinfection.
Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	12/12/2013	0.043	0.043 - 0.043	2	2	ppm	N	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Chromium	12/12/2013	1.61	1.61 - 1.61	100	100	ppb	N	Discharge from steel and pulp mills; Erosion of natural deposits.
Fluoride	12/12/2013	0.465	0.465 - 0.465	4	4.0	ppm	N	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2014	0.07	0.06 - 0.07	10	10	ppm	N	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.
Volatile Organic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Xylenes	2014	0.0015	0 - 0.0015	10	10	ppm	N	Discharge from petroleum factories; Discharge from chemical factories.