CA Labs
Dedicated to Quality

Crisp Analytical, L.L.C.
1929 Old Denton Road
Carrollton, TX 75006
Phone 972-242-2754
Fax 972-242-2798

CA Labs, L.L.C.
11800 Industriplex, Suite 5
Baton Rouge, LA 70809
Phone 225-751-5632
Fax 225-751-5634

Transmission Electron Microscopy Report
Drinking Water Asbestos Analysis
Laboratory Analysis Report
EPA 100.2 Modified Protocol

Woodrow Osceola WSC Pleasant VW
1147 FM 934
Blum, TX 76627-3138

Reference number: CAL13088235NT

The samples, provided for analysis of asbestos in drinking water, were analyzed following Environmental Protection Agency method 100.1 and 100.2 for asbestos structures greater than ten microns in length.

The report lists the sample identification number, filter area, sample volume, area analyzed, structure counts, analytical sensitivity, and the asbestos concentration of structures greater than ten microns in length. The current EPA guideline for compliance is 7.0 million structures per liter (7.0 S/Lx10^6) for asbestos structures greater than ten micron in length.

CA Labs is accredited by the National Voluntary Laboratory Accreditation Program (NVLAP) for selected test methods for airborne fiber analysis (TEM) and by the Texas Commission on Environmental Quality (TCEQ) for analysis of asbestos in drinking water. CA Labs is accredited by the American Industrial Hygiene Association (AIHA LAP, LLC) PLM, TEM and PCM Asbestos fields of testing for industrial hygiene. This analysis is not covered by the scope of accreditation by NVLAP. This method is not covered by the scope of AIHA accreditation for industrial hygiene. The test results relate only to the items described and tested herein. Neither NVLAP, AIHA, nor TCEQ accreditation implies endorsement by any US Government agency.

These results are submitted pursuant to CA Labs' current terms and condition of sale, including the company's standard warranty and limitation of liability provisions and no responsibility or liability is assumed for the manner in which the results are used or interpreted. Unless notified in writing to return the samples covered by this report, CA Labs will store the samples for a period of ninety days before discarding. A shipping and handling fee may be assessed for the return of any samples.

Analysis performed at Crisp Analytical Labs, L.L.C. 1929 Old Denton Road Carrollton, TX 75006. We can be reached after hours by cellular at (214) 564-8366.