

SAMPLE SUMMARY

Workorder Q1305938

Lab ID	Sample ID	Matrix	Date Collected	Date Received
Q1305938001	1335667	Drinking Water	8/20/2013 12:12	8/23/2013
Q1305938002	1348397	Drinking Water	8/20/2013 12:12	8/23/2013

ANALYTICAL RESULTS

Workorder Q1305938

Lab ID: Q1305938001	Date Received: 8/23/2013 07:50	Matrix: Drinking Water
Sample ID: 1335667	Date Collected: 8/20/2013 12:12	Sample Type: SAMPLE
Facility DS01	Location 8852 HWY 171	
Sample Point DBP1-01	Client ID TX1090064	

Parameters	Results	Units	LOD	PQL	MCL	DF	Prepared	By	Analyzed	By	Qual
HALOACETIC ACIDS											
Analysis Desc: 552.2 Haloacetic Acids by GC				Preparation Method: 552.2 Haloacetic Acids by GC							
				Analytical Method: 552.2 Haloacetic Acids by GC							
Bromochloroacetic Acid	<1.00	ug/L	1.00	1.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N
Dibromoacetic Acid	<1.00	ug/L	1.00	1.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N
Dichloroacetic Acid	<1.00	ug/L	1.00	1.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N
Monobromoacetic Acid	<1.00	ug/L	1.00	1.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N
Monochloroacetic Acid	<2.00	ug/L	2.00	2.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N
Total Regulated HAA	<1.00	ug/L	1.00	1.00	60		8/29/2013 08:30	MO	8/30/2013 08:15	JR	
Trichloroacetic acid	<1.00	ug/L	1.00	1.00		1	8/29/2013 08:30	MO	8/30/2013 08:15	JR	N

ANALYTICAL RESULTS

Workorder Q1305938

Lab ID: Q1305938002	Date Received: 8/23/2013 07:50	Matrix: Drinking Water
Sample ID: 1348397	Date Collected: 8/20/2013 12:12	Sample Type: SAMPLE
Facility DS01	Location 8852 HWY 171	
Sample Point DBP1-01	Client ID TX1090064	

Parameters	Results	Units	LOD	PQL	MCL	DF	Prepared	By	Analyzed	By	Qual
Volatiles											
Analysis Desc: E524.2 Volatiles by GC/MS			Preparation Method: E524.2 Volatiles by GC/MS								
			Analytical Method: E524.2 Volatiles by GC/MS								
Bromodichloromethane	<1.00	ug/L	1.00	1.00		1	8/26/2013 17:19	BC	8/26/2013 17:19	BC	N
Bromoform	2.29	ug/L	1.00	1.00		1	8/26/2013 17:19	BC	8/26/2013 17:19	BC	N
Chloroform	<1.00	ug/L	1.00	1.00		1	8/26/2013 17:19	BC	8/26/2013 17:19	BC	N
Dibromochloromethane	1.26	ug/L	1.00	1.00		1	8/26/2013 17:19	BC	8/26/2013 17:19	BC	N
Total Trihalomethanes	3.55	ug/L	1.00	1.00	80		8/26/2013 17:19	BC	8/26/2013 17:19	BC	

ANALYTICAL RESULTS QUALIFIERS

Workorder Q1305938

PARAMETER QUALIFIERS

Lab ID: Q1305938001

N Not Accredited

Lab ID: Q1305938002

N Not Accredited